

# Certificate of constancy of performance

No. 0672-CPR-0051

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the

Construction Product(s): **Overhead Door Closers**  
**„GEZE TS 4000 E“, „GEZE TS 4000 EFS“**

**with the classification enclosed in the annex of this certificate**

produced by or for: **GEZE GmbH**  
**Reinhold-Vöster-Str. 21-29**  
**D-71229 Leonberg**

produced in the manufacturing plant(s): **GEZE GmbH**  
**Reinhold-Vöster-Str. 21-29**  
**D-71229 Leonberg**

**The Certification Body of Materials Testing Institute University of Stuttgart** certifies that all provisions concerning the assessment and verification of constancy of performance described in

Annex ZA  
of the standard(s): **EN 1154:1996 + A1:2002 and EN 1155:1997 + A1:2002**

under system: **1**

for the performances set out above are applied and that the construction product fulfils (products fulfil) all the prescribed requirements for these performances.

This certificate contains 1 page and 1 annex and was first issued on **30.04.2014**. It will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

This document has been translated for informative purpose only. Original version in German. In any case of doubt the German version is valid.

(Stamp)



Stuttgart, 30.04.2014

(Dr. rer. nat. Stefan Lehner)  
Head of Certification Body



# ANNEX

to the certificate of constancy of performance no. 0672-CPR-0051 of 30.04.2014

## Classification of the door closers \*

EN 1154	4	8	6 1	1	1	4
	<b>GEZE TS 4000 E</b>					
EN 1155	3	8	6 1	1	1	4
EN 1154	4	8	6 1	1	1	4
	<b>GEZE TS 4000 EFS</b>					
EN 1155	3	8	6 1	1	1	4

\* The assembly of these door closers can be carried out in normal, frame or parallel arm mounting.

**Note:** The manufacturer has to point out in the assembly and adjustment documents of the door closer, that the door closer should be at least on size 3 for use on fire/smoke door assemblies.

Stuttgart, 30.04.2014

Material Testing Institute – University of Stuttgart  
Department Fire Protection  
Certification Body



(Dr. rer. nat. Stefan Lehner)  
Head of the Certification Body

(Stamp)